



Certificate of Compliance

This certificate is issued for the following:

Plastic Pipe and Fittings for Automatic Sprinkler Systems
POTOK-Fireproff ViolenEx-GF/BF-ViolenEx Pipe and ViolenEx Fittings
Sizes 25, 32, 40, 50, 63, 75, 90, and 110 mm
for use in Wet Pipe Systems in HC-1 Occupancies

Prepared for:

Potok-Pipe Company LLC
st. Elektrozavodskaya, 7
45052, Bashkortostan Republic
Ufa, Zubovo Village, Russia

Manufactured at:

Potok-Pipe Company LLC
st. Elektrozavodskaya, 7
45052, Bashkortostan Republic
Ufa, Zubovo Village, Russia

FM Approvals Class: 1635 (February 2018)

Approval Identification: PR456728

Approval Granted: August 19, 2021

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP – Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

